

RANDOLPH, TONYA

---

**From:** RANDOLPH, TONYA  
**Sent:** Tuesday, June 30, 2015 12:14 PM  
**Subject:** Well & SWP Rated Capacities  
**Attachments:** Wells - Rated Capacities; SWP-Rated Capacity.docx

**From:** Steve Hurst [<mailto:SHurst@speedwayin.gov>]  
**Sent:** Thursday, June 25, 2015 3:48 PM  
**To:** JAWORSKI, MARK  
**Subject:** Well & SWP Rated Capacities

Mark,

Attached are the rated capacities you asked for. Please let us know if we can be of further assistance.

Steve

Speedway Water Works

PWSID 5249008

Surface Water Treatment Plant

Source: Big Eagle Creek

Rated Capacity: 3.0 MGD

Ground Water

Well	Rated Capacity
2	700 gpm @ 220' TDH
3	400 gpm @ 192' TDH
4	350 gpm @ 150' TDH
6	500 gpm @ 213' TDH
7R	300 gpm @ 220' TDH
8R	225 gpm @ 72' TDH
9	300 gpm @ 90' TDH
10R	300 gpm @ 90' TDH
11R	375 gpm @ 87' TDH
12	500 gpm @ 74' TDH
13	500 gpm @ 90' TDH
14R	500 gpm @ 110' TDH
15	250 gpm @ 74' TDH